



3301 NW 55th Street, Ft. Lauderdale, FL 33309 (954-444-3857)

Test Address:

MICHAEL G. STANFORD
123 RUSSELL STREET
HAYWARD, CA 94544

Date Collected: February 17, 2015
Date Received: February 18, 2015
Date Reported: February 23 2015

Email: homeinspector@mytesting.com
Phone: (802) 710-3449
Client Sample #: 01

Project ID: 15B0491
Lab Sample Number: 15B0491-01

Sample Location: KITCHEN SINK

CERTIFICATE OF DRINKING WATER ANALYSIS

CONCLUSION: FAIL

Your drinking water **failed to meet** the Environmental Protection Agency’s (EPA) Primary Drinking Water Standards for human consumption, as well as the FHA/HUD established statutes for maximum contaminant levels for water potability (drinkability).

TEST PARAMETER	RESULTS	ACCEPTABLE RANGE	DETERMINATION
E. coli	Present	None must be present	FAIL
Coliform bacteria	Absent	None must be present	PASS
Lead	None Detected	0 to 14.9 ppb	PASS
Nitrate as Nitrogen	12.76	0 to 9.9 mg/L	FAIL
Nitrite as Nitrogen	3.15	0 to 1.0 mg/L	FAIL

The EPA regulates public water systems and sets the National Primary Drinking Water Regulations (legally enforceable health-related standards). The EPA does not have authority to regulate private drinking water wells. For Federal Housing Authority (FHA) underwriting program for a home with a private well must include as a minimum, 1) Fecal coliforms, including E. coli, 2) Lead (first draw), 3) Nitrites as Nitrogen, and 4) Nitrites as Nitrogen

National Primary Drinking Water Regulations can be found on the web at:
<http://water.epa.gov/drink/contaminants/index.cfm>

John D. Shane Ph.D., Laboratory Director